


-PLATFORM STRUCTURE

BUILDING DD

CONCEPTUAL LANDFILL GAS BUILDING

MITIGATION PLAN (TYPICAL FOR ALL

AREA OF PLATFORM SLAB)



LEGEND

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

PVC END CAP

PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)

RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)

4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)

SEE DETAIL 1, SHEET MT2.01

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.



Phase 1 + 2

Inlet Vents & Wind Turbines

Required (scfm)

238

171

125

215

141

103

45

139

163

365

121

398

261

347

108

101

1369

1259

311

408

294

552

Blower Vacuum

Requirement (" H₂O)

14

12

14

12

14

17

14

12

14

12

14

22

14

22

17

12

22

12

14

12

14

12

22

22

22

17

22

22

Building Type

Parking Garage

Building

Building

Building

Building

Parking Garage

Building

Parking Garage

Building

Parking Garage

Building

Parking Garage

Building | Square Footage | Perimeter | Number of Number of Risers | Blower Flow Rating

1005

429

657

400

554

1018

655

403

468

306

156

601

634

1054

64818

20764

15206

10478

12437

16791

19720

44282

Description REVISIONS

NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA

CITY PLACE SANTA CLARA

CALIFORNIA SANTA CLARA PHASE 1-2 **DEVELOPMENT AREA**

CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN

*77*0611601 12/23/2014 **AS SHOWN** Drawn By Checked By


ubmission Date

MT1.02

Sheet 2 of 10

— FOR PARKING STRUCTURES, PLACE VAPOR MEMBRANE AND VENT PIPING ABOVE STRUCTURAL SLAB (SEE DETAIL 2, SHEET MT2.01).

BUILDING F



CONCEPTUAL LANDFILL GAS BUILDING
MITIGATION PLAN (TYPICAL FOR ALL
PHASE 3 BUILDINGS

NOTES

G

1) For blower flow ratings greater than 400 scfm, install multiple blowers such that each blower is less than 400 scfm.

Inlet Vents & Wind Turbines

Phase 3

Required (scfm)

315

386

381

588

Blower Vacuum

Requirement (" H₂O)

22

Building Type

Building

Building

Building

Building

Building

Building

Building

Parking Garage

2) Frequency of inlet vents, riser and wind turbines, and blower requirements based on conceptual calculations. The design engineer shall determine the actual number and frequency of these components at the time of design.

Building | Square Footage | Perimeter | Number of Number of Risers | Blower Flow Rating |

13

815

860

949

912

1081

1978

36126

38165

44000

44785

46753

46218

71310

180686

PRELIMINARY DRAFT, NOT FOR CONSTRUCTION

Date Description No.

LANGAN

4030 Moorpark Avenue, Suite 210, San Jose, CA 95117

T: 408.551.6700 F: 408.551.0344 www.langan.com

NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO

VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA

ABU DHABI ATHENS DOHA DUBAI ISTANBUL

Langan Engineering, Environmental, Surveying and Landscape Architecture, D.P.C.

Langan Engineering and Environmental Services, Inc.

Langan CT, Inc.

CITY DI ACE

CITY PLACE SANTA CLARA

PHASE 3

DEVELOPMENT AREA

CONCEPTUAL LANDFILL

GAS BUILDING

MITIGATION PLAN

Sheet 3 of 10

Project No. 770611601

Date 12/23/2014

Scale AS SHOWN

Drawn By Checked By

ubmission Date

40 0 20

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.

<u>LEGEND</u>

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM
(SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

PVC END CAP

PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)

RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)


4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)

SEE DETAIL 1, SHEET MT2.01

SCALE: 1" = 150' PLACE VAPOR MEMBRANE AND VENT PIPING WITHIN INTERSTITIAL SPACE ABOVE STRUCTURAL SLAB FOR NON-PARKING STRUCTURES (SEE DETAIL 1, SHEET MT2.01).

- FOR PARKING STRUCTURES, PLACE VAPOR MEMBRANE AND VENT PIPING ABOVE STRUCTURAL SLAB (SEE DETAIL 2, SHEET MT2.01).

BUILDING A



CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN (TYPICAL FOR ALL PHASE 4 BUILDINGS

LEGEND

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

PVC END CAP

PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)

> RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)

4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)

SEE DETAIL 1, SHEET MT2.01

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.

Phase 4							
Building	Square Footage	Perimeter	Number of	Number of Risers	Blower Flow Rating	Blower Vacuum	5 11 F
Letter	(ft ²)	(ft)	Inlet Vents	& Wind Turbines	Required (scfm)	Requirement (" H ₂ O)	Building Type
Α	65160	1084	7	7	239	17	Parking Garage
В	30550	730	5	3	252	17	Building
С	28126	562	4	3	232	17	Building
D	32129	791	5	3	265	17	Building
Е	27950	690	5	3	231	17	Building

NOTES

- 1) For blower flow ratings greater than 400 scfm, install multiple blowers such that each blower is less than 400 scfm.
- 2) Frequency of inlet vents, riser and wind turbines, and blower requirements based on conceptual calculations. The design engineer shall determine the actual number and frequency of these components at the time of design.

PRELIMINARY DRAFT, **NOT FOR** CONSTRUCTION

Description REVISIONS

LANGAN

NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA

CITY PLACE SANTA CLARA

SANTA CLARA CALIFORNIA PHASE 4 **DEVELOPMENT AREA** CONCEPTUAL LANDFILL GAS BUILDING

MITIGATION PLAN *77*0611601 12/23/2014 **AS SHOWN**

MT1.04 Drawn By Checked By ubmission Date


Sheet 4 of 10

(SEE DETAIL 2, SHEET MT2.01).

Phase 5							
Building	Square Footage	Perimeter	Number of	Number of Risers	Blower Flow Rating	Blower Vacuum	D 11.11.11
Letter	(ft ²)	(ft)	Inlet Vents	& Wind Turbines	Required (scfm)	Requirement (" H ₂ O)	Building Type
Α	39750	830	6	4	328	22	Building
В	45000	900	6	5	371	22	Building
С	41047	850	6	4	339	22	Building
D	108546	1249	8	11	398	22	Parking Garage
Е	45000	900	6	5	371	22	Building
F	59067	1020	7	6	217	17	Parking Garage
G	30550	730	5	3	252	17	Building
Н	100638	1270	8	10	369	22	Parking Garage
I	1934	176	1	0	16	12	Building
J	3876	257	2	0	32	12	Building

NOTES

1) For blower flow ratings greater than 400 scfm, install multiple blowers such that each blower is less than 400 scfm. 2) Frequency of inlet vents, riser and wind turbines, and blower requirements based on conceptual calculations. The design engineer shall determine the actual number and frequency of these components at the time of design.



BUILDING A

CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN (TYPICAL FOR ALL PHASE 5 BUILDINGS

LEGEND

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

PVC END CAP

PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)

> RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)

4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)

SEE DETAIL 1, SHEET MT2.01

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.

PRELIMINARY DRAFT **NOT FOR** CONSTRUCTION

Description REVISIONS


NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA

CITY PLACE SANTA CLARA

SANTA CLARA CALIFORNIA PHASE 5 **DEVELOPMENT AREA** CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN

Sheet 5 of 10

*77*0611601 12/23/2014 MT1.05 **AS SHOWN** Drawn By Checked By ubmission Date



SCALE: 1" = 150'

- PLACE VAPOR MEMBRANE AND VENT PIPING WITHIN INTERSTITIAL SPACE ABOVE STRUCTURAL SLAB FOR NON-PARKING STRUCTURES (SEE DETAIL 1, SHEET MT2.01).


- FOR PARKING STRUCTURES, PLACE VAPOR MEMBRANE AND VENT PIPING ABOVE STRUCTURAL SLAB (SEE DETAIL 2, SHEET MT2.01).

	Phase 6							
ıilding	Square Footage	Perimeter	Number of	Number of Risers	Blower Flow Rating	Blower Vacuum	D: I alian ar Trans	
etter	(ft ²)	(ft)	Inlet Vents	& Wind Turbines	Required (scfm)	Requirement (" H ₂ O)	Building Type	-
Α	59454	910	6	6	218	17	Parking Garage	
В	54000	960	6	5	198	14	Parking Garage	
С	45000	900	6	5	371	22	Building	
D	1936	176	1	0	16	12	Building	
Е	45000	900	6	5	371	22	Building	
F	103487	1513	10	10	379	22	Parking Garage	
G	33260	7/1	7	3	27/1	17	Ruilding	

NOTES

- 1) For blower flow ratings greater than 400 scfm, install multiple blowers such that each blower is less than 400 scfm.
- 2) Frequency of inlet vents, riser and wind turbines, and blower requirements based on conceptual calculations. The design engineer shall determine the actual number and frequency of these components at the time of design.

BUILDING C



CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN (TYPICAL FOR ALL **PHASE 6 BUILDINGS**

LEGEND

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

- **PVC END CAP**
- PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)
- RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)
- 4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)
- SEE DETAIL 1, SHEET MT2.01

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.


PRELIMINARY DRAFT **NOT FOR** CONSTRUCTION

Description REVISIONS

CITY PLACE SANTA CLARA

SANTA CLARA CALIFORNIA PHASE 6 **DEVELOPMENT AREA** CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN

*77*0611601 12/23/2014 **AS SHOWN** Drawn By Checked By



— PLACE VAPOR MEMBRANE AND VENT PIPING WITHIN INTERSTITIAL (SEE DETAIL 1, SHEET MT2.01).


— FOR PARKING STRUCTURES, PLACE VAPOR MEMBRANE AND VENT PIPING ABOVE STRUCTURAL SLAB (SEE DETAIL 2, SHEET MT2.01).

Phase 7							
ilding	Square Footage	Perimeter	Number of	Number of Risers	Blower Flow Rating	Blower Vacuum	5 :1: F
etter	(ft ²)	(ft)	Inlet Vents	& Wind Turbines	Required (scfm)	Requirement (" H ₂ O)	Building Type
Α	41281	865	6	4	151	14	Parking Garage
В	41250	850	6	4	340	22	Building
С	52722	954	6	5	435	22	Building
D	63622	1066	7	6	233	17	Parking Garage
E	45000	900	6	5	371	22	Building
F	45000	900	6	5	371	22	Building

NOTES

- 1) For blower flow ratings greater than 400 scfm, install multiple blowers such that each blower is less than 400 scfm.
- 2) Frequency of inlet vents, riser and wind turbines, and blower requirements based on conceptual calculations. The design engineer shall determine the actual number and frequency of these components at the time of design.

BUILDING F



CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN (TYPICAL FOR ALL PHASE 7 BUILDINGS

LEGEND

PASSIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

CONTINGENCY ACTIVE 4" DIAMETER PERFORATED PVC PIPE ABOVE STRUCTURAL PLATFORM (SEE NOTE 5 ON SHEET MT2.02 FOR REQUIRED PERFORATION PATTERN)

PVC END CAP

PASSIVE RISER PIPE TO ROOF (SEE DETAILS ON SHEET MT2.01)

> RISER PIPE TO CONTINGENCY ACTIVE BLOWER ON ROOF (SEE DETAILS ON SHEET MT2.01)

4" DIAMETER SCHEDULE 80 PVC VENT PIPE (SEE DETAILS ON SHEET MT2.01)

SEE DETAIL 1, SHEET MT2.01

NOTES

- 1) VENT PIPES WILL AVOID PILE CAPS AND OTHER FOUNDATION FEATURES, WHERE POSSIBLE, AND ALL AREA OF BUILDING FOOTPRINT WILL BE WITHIN 25 FEET OF VENT PIPE WITH NO OBSTRUCTION TO FLOW (EG, GRADE BEAM IN THE WAY). CONTINGENCY ACTIVE EXTRACTION PIPING PLACED HALFWAY IN BETWEEN RUNS OF VENT PIPING.
- 2) FINAL PIPING LAYOUT WILL BE DESIGNED UPON COMPLETION OF STRUCTURAL DRAWINGS.
- 3) INLET VENTS WILL BE AS EVENLY SPACED AS POSSIBLE AND GREATER THAN 15 FEET FROM DOOR OR WINDOWS.
- 4) RISER AND INLET VENT LOCATIONS WILL BE COORDINATED WITH THE DESIGN TEAM.
- 5) CONTINGENCY (ACTIVE) BLOWER FLOW AND VACUUM REQUIREMENTS SHALL BE REVIEWED FOLLOWING PILOT TESTING OF THE LFG COLLECTION SYSTEM, IF PERFORMED.
- 6) DRAWING SYMBOLS NOT TO SCALE.
- 7) COMPONENTS FOR LANDFILL GAS MITIGATION SYSTEM (LGMS) ARE TYPICAL FOR ALL BUILDINGS.
- 8) BASE DRAWING IS PROVIDED BY LANGAN, 1 NOV 2014.
- 9) FOR DETAIL NOTES, SEE SHEET MT2.02.

PRELIMINARY DRAFT, **NOT FOR** CONSTRUCTION


Description REVISIONS

CITY PLACE SANTA CLARA


SANTA CLARA CALIFORNIA PHASE 7 **DEVELOPMENT AREA** CONCEPTUAL LANDFILL GAS BUILDING MITIGATION PLAN

*77*0611601 12/23/2014 **AS SHOWN**

MT1.07 Drawn By Checked By Submission Date Sheet 7 of 10



12 TYPICAL VENT PIPE CROSSING NOT TO SCALE



LANDFILL MITIGATION SYSTEM CONCEPT AT PLATFORM STRUCTURE NOT TO SCALE

- 1. ALL LOCATIONS AND DIMENSIONS OF BUILDING SLABS, FOOTINGS, AND GRADE BEAMS TO BE CONFIRMED WITH STRUCTURAL DETAILS.
- 2. THE VAPOR BARRIER SHALL BE INSTALLED ACCORDING TO MEMBRANE MANUFACTURER'S SPECIFICATIONS AND QA/QC REQUIREMENTS (E.G., COUPON AND SMOKE TESTING) BY A MANUFACTURER APPROVED APPLICATOR. THE NEED FOR A CARRIER FABRIC AND PROTECTION COURSE WILL BE DETERMINED BY THE VMS DESIGN ENGINEER BASED ON THE TYPE OF VAPOR MEMBRANE SELECTED. IF INSTALLED, CARRIER FABRIC AND PROTECTION COURSE FABRIC SHALL BE PER MEMBRANE MANUFACTURER'S SPECIFICATIONS.
- 3. SLAB PENETRATIONS SHALL NOT BE IN CONTACT WITH AN ADJACENT PENETRATION THAT WOULD PREVENT PROPER SEALING OF THE PENETRATION CIRCUMFERENCE. SLAB PENETRATIONS SHALL BE PREPARED AND STUBBED PRIOR TO MEMBRANE INSTALLATION.
- 4. CRUSHED ROCK SHALL BE ¼"X ¾" (100% PASSING 1-INCH; 90% PASSING ¾-INCH; 10% MAXIMUM PASSING #4). SURFACE OF ROCK LAYER SHALL BE SMOOTH ROLLED PRIOR TO APPLICATION OF THE CARRIER FABRIC. ROCK LAYER SHALL BE 12" MINIMUM.
- 5. HORIZONTAL COLLECTION PIPE SHALL BE SCH. 40 PVC OR SIMILAR QUALITY PLASTIC PIPE. INDICATED SECTIONS OF HORIZONTAL COLLECTION PIPE SHALL BE PERFORATED WITH 5/8 INCH DIAMETER HOLES, THREE HOLES ACROSS THE UPPER ONE—THIRD OF THE PIPE, EVERY THREE INCHES ALONG THE PERFORATED SECTION. AN ADDITIONAL 5/8 INCH DIAMETER HOLE SHALL BE DRILLED ON THE UNDERSIDE OF THE PIPE AT LEAST EVERY TWO LINEAR FEET ALONG THE PERFORATED SECTION TO ALLOW WATER, IF ANY, TO DRAIN FROM THE PIPE. PERFORATED PIPE SHALL BE SLEEVED WITH A GEOTEXTILE FABRIC TO PREVENT ACCUMULATION OF FINES WITHIN THE SYSTEM. HORIZONTAL COLLECTION PIPE SHALL BE PLACED IN THE
- UPPER HALF OF THE CRUSHED ROCK LAYER.

 6. VERTICAL RISER PIPES SHALL BE SUPPORTED AT THE PIPE CHASE WALLS AND HUNG FROM CEILINGS, AS NEEDED. ALL PIPE MATERIALS USED INSIDE THE BUILDING MUST BE CAST IRON PIPE. MINOR (< 5 FEET)
- JOGS IN THE VERTICAL RISER TO AVOID UTILITIES BENEATH ROOF LEVEL ARE ACCEPTABLE.

 7. VERTICAL RISER PIPES SHALL BE LABELED AS "CONTAINS METHANE GAS AND VAPORS; DO NOT BREAK OR
- 8. THE VERTICAL RISER PIPE TO THE WIND-ASSISTED OR BLOWER-ASSISTED VENTS SHALL BE 4 INCH DIAMETER CAST IRON PIPE (MAY TRANSITION AT ROOF LEVEL TO PAINTED SCHEDULE 80 PVC). VERTICAL RISER PIPE SHALL EXTEND TO AN ELEVATION ABOVE ROOF LEVEL SUCH THAT IT EXTENDS A MINIMUM OF 12 INCHES ABOVE SURROUNDING PARAPET OR WINDSCREEN AND IS OUTSIDE OF ANY WIND SHADOW. THE RISER PIPE SHALL BE LOCATED A MINIMUM OF 15 FEET FROM ANY FRESH AIR INTAKES.
- 9. THE VERTICAL RISER PIPE TO THE WIND-ASSISTED OR BLOWER-ASSISTED VENTS SHALL BE SECURED WITH FOUR 1/8 INCH AIRCRAFT CABLES TO PREVENT EXCESSIVE MOVEMENT. OTHER APPROPRIATE FASTENING MEASURES MAY BE USED WITH APPROVAL FROM A/E TEAM.
- 10. TEST PORTS SHALL BE INSTALLED ON VERTICAL RISER PIPES, 36 INCHES ABOVE ROOF LEVEL, FOR AIR SAMPLING. THE TEST PORT FOR THE BLOWER ASSISTED RISER SHALL BE INSTALLED AS SHOWN IN DETAIL 10. TEST PORT SHALL ALSO BE INSTALLED AT GROUND FLOOR LEVEL, IF THE RISER CAN BE PRACTICALLY ACCESSED AT THIS LOCATION.
- 11. THE WIND-ASSISTED TURBINE ON TOP OF THE 4 INCH PVC RISER SHALL BE 12 INCH DIAMETER STAINLESS STEEL (MCMASTER-CARR CAT#1992K48, OR EQUIVALENT) AND SHALL BE SECURED TO THE TOP OF THE RISER
- 12. BLOWER SHALL MEET FLOW RATE AND PRESSURE REQUIREMENTS AS SHOWN ON SHEETS MT1.02 TO MT1.07, WITH HAZARDOUS LOCATION ENCLOSURE. BLOWER MUST BE UL LISTED, CLASS I, GROUP D TYPE. THE BLOWER WILL BE SCHEDULED FOR ROUTINE (MONTHLY) OPERATION TO PREVENT UNWANTED MOISTURE AND PRECIPITATION BUILDUP.
- 13. PERIMETER INLET VENTS SHALL BE LOCATED A MINIMUM 15 FEET FROM DOORS OR WINDOWS. IF THE 15-FOOT MINIMUM DISTANCE IS NOT POSSIBLE, THE NEED FOR CHECH-VALUES TO PREVENT RELEASE OF SUBSLAB VAPOR TO THE EXTERIOR SHALL BE CONSIDERED.
- 14. PERIMETER INLET VENTS SHALL BE FITTED WITH A VENT CAP TO KEEP OUT DEBRIS BUT ALLOW AIR TO ENTER THE PIPE. INLET VENT SHALL TERMINATE 2 FEET MIN ABOVE EXTERIOR GRADE.
- 15. DURING SUBGRADE PREPARATION, PROTRUDING OBJECTS WILL BE CRUSHED AND/OR REMOVED AND ANY RESULTING VOIDS WILL BE FILLED WITH ADDITIONAL GRAVEL OR ACCEPTABLE FILL. SUBGRADE SHALL BE PREPARED WITH A GRADING TOLERANCE OF \pm 0.1 FOOT.

PRELIMINARY DRAFT, NOT FOR CONSTRUCTION

Description

REVISIONS

4030 Moorpark Avenue, Suite 210, San Jose, CA 95117
T: 408.551.6700 F: 408.551.0344 www.langan.com

NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA ABU DHABI ATHENS DOHA DUBAI ISTANBUL

CITY PLACE SANTA CLARA

Langon Engineering, Environmental, Surveying and Landscape Architecture, D.P.C. Langon Engineering and Environmental Services, Inc. Langon CT, Inc. Langon International LLC Collectively known as Langon

CONCEPTUAL LANDFILL
GAS BUILDING
MITIGATION SYSTEM
DETAILS

CALIFORNIA

Project No.
770611601

Date
16/20/200134

Scale
AS SHOWN

Drawn By Checked By
AC | Diff

ubmission Date

Filename: \\langan.com\data\SJ\data6\770611601\Cadd Data - 770611601\SheetFiles\Methane Mitigation\MT2.01 to MT3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS2.02

6/30/2015

CONCEPTUAL BUILDING ELEVATION

TABLE 1 - DETECTOR SPACING FOR 1ST FLOOR OF RESIDENTIAL/COMMERCIAL BUILDING

		NUMBER OF DETECTORS				
	ROOM FLOOR AREA OR CONCEALED SPACE AREA (square feet)	WITH HEATING, VENTILATION OR AIR CONDITIONING	WITHOUT HEATING, VENTILATION OR AIR CONDITIONING			
	10,000 and More	Minimum of 3 Detectors plus one for every 20,000 and fraction thereof in excess of 10,000	Minimum of 6 Detectors plus one for every 2,500 and fraction thereof			
	More Than 5,000 and Less Than 10,000	3 Detectors	Minimum of 2 Detectors plus one for every 2,500 and fraction thereof			
/	More Than 1,000 and Up to 5,000	2 Detectors	Minimum of 1 Detector plus one for every 2,500 and fraction thereof			
	0 and Up to 1,000	1 Detector	1 Detector			

Rooms connected by a shared HVAC system are considered a single "room floor area" for the purpose of determining detector frequency.

TABLE 2 - DETECTOR SPACING IN INTERSTITIAL SPACE

INTERSTITIAL SPACE AREA (square feet)	NUMBER OF DETECTORS
10,000 and More	Minimum of 3 Detectors plus one for every 20,000 and fraction thereof in excess of 10,000
More Than 5,000 and Less Than 10,000	3 Detectors
More Than 1,000 and Up to 5,000	2 Detectors
0 and Up to 1,000	1 Detector

TABLE 3 - DETECTOR SPACING FOR 1ST FLOOR OF PARKING STRUCTURES

CONCEALED SPACE AREA (square feet)	NUMBER OF DETECTORS	
10,000 and More	Minimum of 3 Detectors plus one for every 20,000 and fraction thereof in excess of 10,000	
More Than 5,000 and Less Than 10,000	3 Detectors	
More Than 1,000 and Up to 5,000	2 Detectors	
0 and Up to 1,000	1 Detector	

* Table applies to enclosed areas of parking garages. For open air portion of the garage, install methane detectors of frequency of 1 per 50,000 sf.

NOTES:

- 1. THE METHANE SENSOR NETWORK SHALL INCLUDE LOW LEVEL, HIGH LEVEL AND FAULT ALARMS. AN AUDIBLE HORN ALARM SHALL SOUND DURING HIGH ALARM ACTIVATION.
- 2. LOW ALARM ACTIVATION SHALL OCCUR AT 10% OF THE LOWER EXPLOSION LIMIT (LEL) OF METHANE GAS AND SIGNALS SHALL BE SENT TO THE ROOFTOP CONTROLLER TO ACTIVATE START OF CONTINGENCY BLOWER.
- 3. FAULT ALARM ACTIVATION SHALL OCCUR AT LOSS OF SENSOR SIGNAL, LOSS OF CONTROLLER POWER, AND/OR LOSS OF SAMPLE DRAW ON SENSORS USING REMOTE SAMPLE TECHNOLOGY. USING FAULT ALARM, A SIGNAL SHALL BE SENT TO THE BUILDING ENGINEER TO INSPECT/REPAIR SYSTEM. 4. HORN ALARM ACTIVATION SHALL OCCUR AT 25% OF THE LEL OF METHANE GAS AND SIGNALS SHALL BE SENT TO THE FIRE
- ALARM CONTROL PANEL (FACP). THE FACP WILL ACTIVATE BUILDING HORN/STROBES AT THE FACILITY ENGINEERING OFFICE, AND SEND AN ALARM TO A 24-HOUR MONITORING COMPANY INDICATING A "25% LEL METHANE GAS ALARM".
- 5. ALARM RELAYS CONTACTS SHALL BE WIRED OPEN UNDER NORMAL CONDITIONS AND SHALL CLOSE ON ALARM OR LOSS OF
- 6. ALL SENSOR AND CONTROL WIRE PENETRATIONS SHALL MEET CURRENT WALL, FLOOR, AND CEILING PENETRATION
- REQUIREMENTS AND SHALL BE SEALED WITH "APPROVED FREE RATED CAULKING".
- 7. DESIGN ENGINEER SHALL REVIEW ALARM THRESHOLDS AND ADJUST AT THE TIME OF DESIGN. SENSORS WITHIN INTERSTITIAL
- SPACE MAY ALARM AT HIGHER METHAN LEVELS, AT THE DISCRETION OF THE DESIGN ENGINEER.

PRELIMINARY DRAFT **NOT FOR** CONSTRUCTION

Description REVISIONS

NEW JERSEY NEW YORK CONNECTICUT PENNSYLVANIA OHIO VIRGINIA WASHINGTON DC FLORIDA NORTH DAKOTA CALIFORNIA

CITY PLACE SANTA CLARA

CALIFORNIA

CONCEPTUAL METHANE **GAS BUILDING** MONITORING SYSTEM

*77*0611601 16//20//200154 MT3.01 **AS SHOWN** Drawn By Checked By

ubmission Date 6/30/2015

Filename: \\langan.com\data\SJ\data6\770611601\Cadd Data - 770611601\SheetFiles\Methane Mitigation\MT2.01 to MT3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Langan.stb Layout: VMS3.01 Details.dwg Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Date: 7/13/2015 Time: 14:07 User: cyoung Style Table: Cyoung Style Tab